

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0935:112

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Nailor Industries, 4714 Winfield, Houston TX 77039
Contact: John Young (281) 590-1172 Fax (281) 590-3086

DESIGN: Models 1220 and D1220 combination fire and leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations.

<i>Installation</i>		<i>Single Section</i>		<i>Height</i>		<i>Multiple Section</i>		<i>Height</i>	
		<i>Width</i>		<i>Min.</i>	<i>Max.</i>	<i>Width</i>		<i>Min.</i>	<i>Max.</i>
		<i>Min.</i>	<i>Max.</i>			<i>Min.</i>	<i>Max.</i>		
V	1-1/2h	12"	36"	8"	48"	12"	144"	16"	96"
V	3h	12"	36"	8"	48"				
H	1-1/2h	12"	32"	8"	48"	12"	144"	16"	96"
H	3h	12"	32"	8"	48"				

RATING: 1-1/2, 3 hour
Class I and Class II, 250° F and 350° F

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as 1-1/2, 3 hour fire rated and Class I and II leakage rated dampers for use with listee's listed damper operators.

08-02-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager